

ਦਫਤਰ ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ
ਪ੍ਰਾਂਤਕ ਮੰਡਲ ਭ ਤੇ ਮ ਸ਼ਾਖਾ,
ਫਿਰੋਜ਼ਪੁਰ 01632-292529



75
Azadi Ka
Amrit Mahotsav

ਲੋਕ ਨਿਰਮਾਣ ਵਿਭਾਗ ਪੰਜਾਬ
E-Mail ID- eepdfzrpdpb@gmail.com

OFFICE OF EXECUTIVE ENGINEER
Provincial Division PWD B&R Br,
Ferozepur 01632-292529

ਪਿੱਠ ਅੰਕਣ ਨੰ: 1979-80

ਮਿਤੀ: 22/08/22

ਉਪਰੋਕਤ ਦਾ ਉਤਾਰਾ ਹੇਠ ਦਰਸਾਇਆ ਨੂੰ ਸੂਚਨਾ ਅਤੇ ਲੋੜੀਂਦੀ ਕਾਰਵਾਈ ਹਿੱਤ ਭੇਜਿਆ ਜਾਂਦਾ ਹੈ:-


1. Chairman, The Hero Public School, Makhu, Distt. Ferozepur
ਨੱਥੀ/ਨਕਸ਼ਾ ਮੂਲ ਰੂਪ ਵਿੱਚ
2. ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਉਸਾਰੀ ਉਪ ਮੰਡਲ, ਭਤੇਮ ਸ਼ਾਖਾ, ਜੀਰਾ ਨੂੰ ਉਹਨਾਂ ਦੇ ਪੱਤਰ ਨੰ: 290
ਮਿਤੀ 17.08.2022 ਦੇ ਹਵਾਲੇ ਵਿੱਚ ਸੂਚਨਾ ਹਿੱਤ।

ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ,
ਪ੍ਰਾਂਤਕ ਮੰਡਲ, ਭਤੇਮ ਸ਼ਾਖਾ,
ਫਿਰੋਜ਼ਪੁਰ

Sub Divisional Engineer
Constn. Sub Division
Ferozepur




- d) Weather underground static water storage tank of capacity : YES/NO ✓
50000 Ltr. (if converted are excess 1600 Sqm).
- e) Weather over head tank of capacity 10000 Ltr. Exists (in case of : YES/NO ✓
hose reel) 20000 Ltr.
- e) Weather one electric and one diesel Pump of 3 Kg/ cum : YES/NO ✓
pressure of capacity 1620 LPM. One electric pump of capacity
180 LPM exist near underground static tank.
- g) Weather a pump 3 kg/ cum pressure & 450/500 LPM exist near : YES/NO ✓
over head tank.



Signature with Stamp of the seal
Of the School/Institution.

PART-II

(To be filled by the S.D.E. of PWD (B&K) Department)

- a) I have visited the above mentioned school on dated11/8/2022..... And have
visually inspected it from all angles of safety and find it fit for normal use as School buildings.
- b) In case any addition/ alteration or expansion and modifications to this buildings is to be carried
out, the same be carried out under the supervision of a qualified Engineer and this certificate
may be reobtained after the completion from the undersigned.
- c) In case the building is affected by food, or if there is settlement of walls/ foundations or
sagging of roofs etc. immediate inspection of the undersigned by arranged to check the stability
and safety of the building.
- d) This building can be safety occupied for normal use upto (indicate upto which it can be used)
.....31/3/2023.....


Sub Divisional Engineer,
PWD (B&K) Branch,
Constn. Sub Division, PWD B & R
Zira



PROFORMA FOR THE SAFETY OF SCHOOL BUILDING

PART-1

(To be filled by the Head of School/institute)

1. Name of the School **The Hero Public School**
2. Location **NH 54, Makhu (Talwandi Nepal)**
3. Plot Area **47 Kanal**
4. Plinth Area **81657 sq ft**
5. Number of Storey's **4 + 2**
6. Year of construction of building **2017**
7. If the building has been constructed under the supervision

of the qualified Engineer, the following details may be given

- (a) Name of the Engineer with qualification. **Er. Gurwinder Singh B.E**
- (b) Address of Engineer **Male road, Fir city (Civil)**
- (c) Set of Structural drawings used in the construction, if available **Three copies attached**
- (d) Name & address of Architect with qualification

8. Whether the building has been constructed for the purpose

- (a) School YES/NO
- (b) Residential purpose and converted for use as a School YES/NO

9. Materials used for roofs

- (a) R.C.C Slabs/R.B.C Slabs YES/NO
- (b) R.S Joist & Battons YES/NO
- (c) Wooden joists & Battons YES/NO

10. Materials used for walls

- (a) Mud Mortar YES/NO
- (b) Cement Mortar YES/NO
- (c) Lime Mortar YES/NO

11. Flooring

- (a) Conglomerate YES/NO
- (b) Terrazzo YES/NO
- (c) Brick paving YES/NO

12. A detailed drawing indicating dimensions of the rooms
Along with size and location of doors and windows (Attached).

13. For Fire Safety

- (a) Weather the width of the staircase is 1.5 Mtr. YES/NO
- (b) Weather portable fire extinguisher exists. YES/NO
- (c) Weather school building is free from inflammable & toxic material. YES/NO
- (d) Weather cooking of food is done at a safe place. YES/NO
- (e) Weather any thatch of combustible material has been used. YES/NO

14. Requirement for fire protection Arrangements under NBC

(For Building height less than 15 Metre)

- (a) Weather Hose Reel provided YES/NO
- (b) Weather down comer provided YES/NO
- (c) Whether Automatic Sprinkler provided YES/NO



Sub. Divisional Engineer
Constn. Sub Divn. PWD (B&R) Br.

